

VIZY7.EX15151 - Steel Sprinkler Pipe Certified for Canada

Steel Sprinkler Pipe Certified for Canada

[See General Information for Steel Sprinkler Pipe Certified for Canada](#)

JOSH GLOBAL CORP

EX15151

43 Ciaozihtou

Taibao City

Chiayi Hsien, 612 TAIWAN

Schedule 10 (black or galvanized), Type E, Grade A, steel pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4 and 6 in. sizes.

Model Module-Flow, steel pipe in the 1, 1-1/4, 1-1/2, 2, 3OD (76.1mm), 3 and 4 in. nominal diameter for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber gasketed fittings as indicated under the category Fittings, Rubber Gasketed (VIZM) when installed in accordance with the fitting manufacturer's specifications where rated pressures and corrosion resistance ratios (CRR) are as follows:

Pipe Size, in.	Rated Pressure, kPa	CRR Unthreaded
1	2070	0.12
1-1/4	2070	0.10
1-1/2	2070	0.09
2	2070	0.07
3OD (76.1mm)	2070	0.07
3	2070	0.06
4	2070	0.04

Last Updated on 2019-05-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."